

MQ Power - DCA 15SPXU4 One Link Install

Parts list:


- | | |
|-----------------------------------|---|
| (1) One Link with magnetic mounts | (1) Battery wiring harness with inline fuse |
| (1) 4G LTE Antenna/GPS Antenna | (1) OLSC005 serial cable |
| (2) Lever wire connectors | (2) Zip ties |

Installation Instructions:

1. Put the generator in stop mode.
2. Disconnect the positive battery terminal. (**Do not reconnect the positive battery terminal until step 14.**)
3. Using the magnetic mounts, mount the One Link inside of the generator enclosure close to the controller. (**Be sure the mounting location is away from weather exposure.**)
4. Connect the ring connector on the **red** wire of the battery wiring harness to the positive (+) battery terminal.
5. Connect the ring connector on the **black** wire of the battery wiring harness to the negative (-) battery terminal.
6. Route the **brown** wire and **blue** wire from the One Link I/O cable to the battery wiring harness installed in steps 4 and 5.
7. Using one of the included lever wire connectors, connect the bare **black** wire from the battery wiring harness to the bare **blue** wire from the One Link I/O cable.
8. Using one of the included lever wire connectors, connect the bare **red** wire from the battery wiring harness to the bare **brown** wire from the One Link I/O cable.
9. Route the **brown** wire with white stripe from the One Link I/O cable to the back of the Hertz Meter.
10. Route the **red** wire with white stripe from the One Link I/O cable to the back of the Hertz Meter.
11. Mount the LTE/GPS antenna on the top of the generator.
12. Connect the LTE antenna cable to the top connector on the right side of the One Link.
13. Connect the GPS antenna cable to the bottom connector on the right side of the One Link.
14. Reconnect the positive battery terminal to the battery.

At this time the One Link will power up and begin communicating with the generator. Please allow 5-10 minutes for the One Link to establish a connection to the internet, and then check the activation screen or your One Link account to ensure the generator's vitals update and the One Link is transmitting data.

MQ Power - DCA 15SPXU4



TITLE: MQ Power - DCA 15SPXU4		REV: 1.0
	Company: Zabatt Power Systems	Sheet: 1/1
	Date: 2021-10-28	Drawn By: Yong Kim

MQ Power - DCA 15SPXU4 One Link Wire Legend

MQ Power - DCA 15SPXU4 One Link Wire Legend						
			Old Gray I/O Cable	New Black I/O Cable	Generator	
Description	Illustration	One Link Function	Color	Color	Location	Generator Function
Battery +		Battery +	Red	Brown	Battery +	Battery +
Battery -		Battery -	Black	Blue	Battery -	Battery -
K1COM		K1COM	Red/White Stripe	Orange		
K1NO		K1NO	Red/Black Stripe	Green		
K2COM		K2COM	Orange	Yellow		
K2NC		K2NC	Orange/Black Stripe	Gray		
DI1		Close to Ground	Black/White Stripe	Pink		
DI2		Close to Ground	Blue/Black Stripe	Red		
DI3		Close to Batt +	Blue/White Stripe	Black		
DI4		Close to Batt +	Blue	White		
DI5		Close to Batt +	Green/Black Stripe	Purple		
A1		0-5V	Green	Light Green		
A2		0-5V	Green/White Stripe	Black/White Stripe		
L1		AC Voltage L1	White	Brown/White Stripe	Back of HZ Meter	
L2		AC Voltage L2	White/Black Stripe	Red/White Stripe	Back of HZ Meter	AC Voltage Sensing(Includes Hz and