



Installation Instructions:

- 1. Put the generator in stop mode.
- **2**. Disconnect the positive battery terminal. (Do not reconnect the positive battery terminal until step 14.)
- **3**. Using the magnetic mounts, mount the One Link inside of the generator enclosure close to the controller. (Be sure the mounting location is away from weather exposure.)
- **4**. Connect the ring connector on the red wire of the battery wiring harness to the positive (+) battery terminal.
- **5**. Connect the ring connector on the **black** wire of the battery wiring harness to the negative (-) battery terminal.
- **6**. Route the **brown** wire, **orange** wire, and wire from the One Link I/O cable to the battery wiring harness installed in steps 4 and 5.
- **7**. Using one of the included lever wire connectors, connect the bare **black** wire from the battery wiring harness to the **orange** wire and **black** wire from the One Link I/O cable.

Panel:



Parts List:



OLM003B



OLSC005





Installation Instructions(cont.)

- . Using one of the included lever wire connectors, connect the bare **red** wire from the battery wiring harness to the bare **brown** wire from the One Link I/O cable.
- . Route the **black** wire from the One Link I/O cable to Terminal 6.
- . Route the **white** wire from the One Link I/O cable to Terminal 7.
- 11. Route the purple wire from the One Link I/O cable to Terminal 8.
- . Route the **brown** wire with **white** stripe from the One Link I/O cable to Terminal 21.
- .Route the **red** wire from the One Link I/O cable to Terminal 23.
- . Route the wire from the One Link I/O cable to Terminal 30.
- . Mount the LTE/GPS antenna on the top of the generator.
- . Connect the LTE antenna cable to the top connector on the right side of the One Link.



Lever Connectors(2)



Installation Instructions(cont.)

- **17**. Connect the GPS antenna cable to the bottom connector on the right side of the One Link.
- **18**. Plug the 15 pin connector into the bottom of the One Link, and tighten both screws using a flathead screwdriver.
- **19**. Reconnect the positive battery terminal to the battery.

At this time the One Link will power up and begin communicating with the generator. Please allow 5-10 minutes for the One Link to establish a connection to the internet, and then check the activation screen or your One Link account to ensure the generator's vitals update and the One Link is transmitting data.



TX Installation

- 1. Connect the red wire from the OneLink I/O cable to the Normally Closed terminal on J18.
- **2**. Connect the Common terminal on J18 to ground.
- **3.** Connect the Common terminal on S1 to ground.
- **4.** Connect the **pink** wire from the OneLink I/O cable to the Normally Open contact on S1.